

"QUALITY PUMPS SINCE 1939"

Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.

ZOELLER
PUMP CO.



SECTION: 4.10.003

FM1663

1006

Supersedes

0603

MAIL TO: P.O. BOX 16347 • Louisville, KY 40256-0347
SHIP TO: 3649 Cane Run Road • Louisville, KY 40211-1961
(502) 778-2731 • 1 (800) 928-PUMP • FAX (502) 774-3624

visit our web site:
www.zoeller.com

FEATURES

- Allows you to install two automatic pumps up to ½ HP, 115V, 12 amps, single phase and alternate their use.
- Provides for extended pump life.
- NEMA 1 enclosure for indoor use.
- Special design allows use in humid areas (i.e. basements).

EXTRA PROTECTION

- True alternation allows each pump to be used equally, not timed.
- Second pump will automatically operate if first pump should fail.

ALARMS

- Separate power cord and circuit for high-water alarm.
- Built in alarm automatically sounds if one of the pumps should fail and calls for the second pump to run during a pump failure.
- Alarm sounds and lights up when alarm switch is activated.

INDICATOR LIGHTS

- Tells you if the power is on, which pump is operating and alarm status.

EASY INSTALLATION

- Plug automatic pumps into appropriate receptacles on the alternator panel. Install the alarm float provided with the unit and plug in the **Smart Pak Plus** to a separate power supply. No special wiring required. Plug alarm cord into separate outlet on a different circuit.

NEW!

SMART PAK PLUS

RESIDENTIAL ALTERNATOR SYSTEM




ALARM FLOAT




Part Number: 10-0804
Shipping Weight: 5 lbs.

EXTRA PROTECTION

1. Unpack unit and inspect for damage.
2. Review figure 1 for a typical installation.
3. Follow instructions included with each pump for proper pump installation. Test pump on and off cycle several times to ensure proper pump cycling.
4. Mount unit on wall within reach of pump's cord.
5. Install alarm switch in pit on one of the discharge pipes. Set the alarm to sound above the on level of the pumps but below the inlet to the pit.
6. Plug the alarm float switch cord and pump cords into appropriate places on the alternator panel.
7. Plug the power cord into a properly grounded outlet.
8. Plug alarm into a separate grounded outlet or a different branch circuit than the pump.
9. Check system for proper operation as outlined below.

 **WARNING** All installations must be in accordance with the National Electric Code, and any other applicable state and local electrical requirements.

 **WARNING** Do not remove ground pin. Severe electrical shock could occur.

Normal Operation

The control unit will supply 115 VAC to pump 1 and the pump 1 lamp will illuminate. Power will remain supplied to pump 1 until the float switch turns on again. At this point, the control unit will switch power supply from pump 1 to pump 2. Power will remain supplied to pump 2 until the float switch turns off and then on again, at which time power will be switched back to pump 1. The control unit will continue to alternate between pumps 1 and 2, in this manner, until an alarm is detected.


Alarm Mode - Pump Running (This indicates that a pump may be in need of repair or the pump switches are dragging - realign.)

If a pump is running and the fluid level continues to rise, closing the alarm float switch, the unit will sound an alarm for 15 seconds and illuminate an alarm lamp. In addition, power will be switched from current energized pump to other pump. The alarm lamp will remain illuminated until the alarm float switch turns off.

Alarm Mode - Upon Power Up

If an alarm condition exists when the controller is plugged in or after a power outage, the alarm buzzer will sound for 15 seconds or until the float signal is no longer detected. The controller activates a pump relay and waits 0.25 seconds and checks to verify the pump is drawing current. While the alarm float signal is detected, the unit will alternate pumps every 60 seconds until the alarm condition is eliminated. Once the alarm is cleared, the unit will revert to normal mode of operation.

Figure 1: Typical Installation



www.zoeller.com

ZOELLER
PUMP CO.

MAIL TO: P.O. BOX 16347
Louisville, KY 40256-0347
SHIP TO: 3649 Cane Run Road
Louisville, KY 40211-1961
(502) 778-2731 • 1 (800) 928-PUMP
FAX (502) 774-3624

Manufacturers of . .

"QUALITY PUMPS SINCE 1939"